



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**



TC-12273

Telephone No : 0497 2704380
email : kwaqclabkannur@gmail.com

ULR-TC-1127324000004234F

Report No - KWA/QA/R/08/4234/I/31/0049	Date : 02/08/2024
Customer Name and Address	1. Date of receipt : 01/08/2024
Kannur Salafi B.Ed College Village Mukku Koodali(PO)-670592 (NON-DOMESTIC PURPOSE)	2. Sampling Provided by : Customer(QUA_155270)
	3. Sample Code : 2904
	4. Sample : Drinking Water
	5. Source of Sample : Open Well
	6. Sample quantity : 2 litre
	7. Test performing dates
	From : 01/08/2024 To : 02/08/2024

Sl. No	Characteristic	Test Method	Requirement as per IS 10500-2012		Result
			Acceptable Limit	Permissible Limit in the absence of alternate source	
15	Fluoride (as F), mg/l, Max	APHA24th Edition 4500-F-D, SPADNS Method	1	1.5	-
16	Iron (as Fe), mg/l, Max	IS 3025 (part 53) -2024 Second Edition	1	No relaxation	0.06
17	Nitrate (as NO ₃), mg/l, Max	APHA24th Edition 4500 NO ₃ -B(UV Screening Method)	45	No relaxation	13.31
18	Ammonia (as NH ₃ - N), mg/l, Max	IS 3025 (Part 34)-1988 (Reaffirmed 2019)	0.5	No relaxation	-

Sl. No	Characteristic	Test Method	Result
1	Phosphorous (as P) , mg/l	IS 3025 (part 31/sec 1): 2022	-
2	Dissolved Oxygen , mg/l	IS 3025(Part 38)-1989(Reaffirmed 2019)	-
3	Total Suspended Solids ,mg/l	IS 3025(Part17)-Second revision 2022	-
4	Oil and Greese, mg/l	IS 3025 (Part 39)- 2021	-
5	Bio chemical Oxygen Demand, mg/l	IS 3025(Part 44)-2023	-
6	Chemical Oxygen Demand, mg/l	IS 3025 (Part 58)-2022	-
7	Acidity, mg/l	IS 3025 (part 22) -1986 (Reaffirmed 2019)	-

REMARKS:
The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

 Rekha V K
 Quality Manager
 SR SANITARY CHAMBER
 QUALITY CONTROL DISTRICT LAB
 KERALA WATER AUTHORITY
 KANNUR

SECRETARY
 ISLAHI TRUST
 Reg. No. 105/96
 Kannur - 670 001, Kerala

Date: 29.07.2023
 Page 1/1

KWA/QC/KNR/R/17
 Issue No: 03
 Issue Date: 29.07.2023
 Principal
 Salafi English Medium School
 P.O. Chekkikulam
 For Salafi Educational Complex



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**



TC-12273

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

ULR- TC-1127324000004234F

Report No - KWA/QA/R/08/4234/J/31/0049	Date : 02/08/2024
Customer Name and Address	1. Date of receipt : 01/08/2024
Kannur Salafi B.Ed College Village Mukku Koodali(PO)-670592 (NON-DOMESTIC PURPOSE)	2. Sampling Provided by : Customer(QUA_155270)
	3. Sample Code : 2904
	4. Sample : Drinking Water
	5. Source of Sample : Open Well
	6. Sample quantity : 2 litre
	7. Test performing dates
	From : 01/08/2024 To : 02/08/2024

SI NO	Characteristic	Test Method	Requirement as per IS 10500-2012		Result
			Acceptable Limit	Permissible Limit in the absence of alternate source	
1	Taste	IS 3025 (Part 8)-2023 Second Revision	Agreeable	Agreeable	-
2	Colour ,HAZEN Units, Max	IS 3025 (part 04) -2021	5	15	-
3	Odour	IS 3025 (part 5) -2018	Agreeable	Agreeable	-
4	Turbidity ,NTU, Max	IS 3025(part 10)-2023	1	5	0.51
5	pH	IS 3025 (part 11) - 2022	6.5 to 8.5	No relaxation	5.51
6	Total Alkalinity (as CaCO ₃), mg/l, Max	IS 3025 (part 23) -2023	200	600	-
7	Total Dissolved Solids (TDS), mg/l, Max	IS 3025 (part 16) -2023 Second Revision	500	2000	-
8	Total Hardness (as CaCO ₃), mg/l, Max	IS 3025 (part 21) -2009 Second Revision	200	600	21.70
9	Calcium (as Ca), mg/l, Max	IS 3025 (part 40) -1991 (Reaffirmed 2019)Amendment No 1 2004	75	200	-
10	Magnesium (as Mg), mg/l, Max	IS 3025 (part 46) -2023	30	100	-
11	Chloride(as Cl), mg/l, Max	IS3025(part 32)-1988 (Reaffirmed 2019)	250	1000	13.70
12	Electrical Conductivity at 25°C, micro mhos/cm	IS 3025 (part 14) -2013 (Reaffirmed 2019)			82.31
13	Residual Free Chlorine, mg/l, Min	IS 3025 (part 26) -2021	0.2	1	-
14	Sulphate (asSO ₄), mg/l, Max	IS 3025 (part 24/sec 1) :2022	200	400	-

Remarks:
The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Rekha V K
Quality Manager

KWA/QC/KNR/R/17

* End Of Report*

Issue No: 03

Issue Date: 29.07.2023

Principal
Salafi English Medium School
P.O. Chekkikulam
Kannur - 670592

SR. SANITARY CHEMIST
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
KANNUR-1

SECRETARY
ISLAHI TRUST
Reg. No. 105/86, Bank Road
Kannur - 670 004



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

Report No - KWA/QA/R/08/4234/1/52/531		Date : 02/08/2024			
Customer Name and Address		1. Date of receipt : 01/08/2024			
Kannur Salafi B.Ed College Village Mukku Coodali(PO)-670592 NON-DOMESTIC PURPOSE)		2. Sampling Provided by : Customer(QUA_155270)			
		3. Sample Code : 2904			
		4. Sample : Drinking Water			
		5. Source of Sample : Open Well			
		6. Sample quantity : 100 ml			
		7. Test performing dates			
		From: 01/08/2024		To: 02/08/2024	
Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	47
2	E.Coli	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

[Signature]
Bacteriologist

* End Of Report*

KWA/QC/KNR/R/17

Issue No: 02

Issue Date: 01.06.2021

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB KANNUR
KWA WATER AUTHORITY
KANNUR 670 012
Page 3 of 3

[Signature]

Principal
Salafi English Medium School
P.O. Chekkikulam
Kannur - 670592

[Signature]
SECRETARY
ISLAHI TRUST
Reg. No. 105/86, Bank Road
Kannur - 670 001, Kerala State